


**MONTHLY REPORT  
CITY & SOUTHWEST ACOUSTIC ADVISOR**

<b>For period:</b>	<b>May 2017</b>	<b>Authorisation:</b>	
<b>Prepared by:</b>	Dave Anderson		
<b>Date of issue:</b>	7 May 2017		

***Acoustic Advisor Activity***

- Review and endorsement of Construction Noise and Vibration Management Plan (CNVMP) for Metropolitan Demolitions work at Martin Place
- Review and approval of Out of hours work (OOHW) applications for:
  - Pitt Street North – awning removal, hoarding installation and cross-over installation at 175 Castlereagh St
  - Martin Place North - awning removal and hoarding installation at Castlereagh, Hunter and Elizabeth Streets
  - Sydney Yard Access Bridge – hoarding construction and tree removal
- Review and comment on
  - Martin Place North – OOHW application for Saturday afternoons
  - Sydney Yard Access Bridge – OOHW application for piling
- Ongoing discussion, including meetings, with noise and vibration consultants for Delta and Metropolitan demolition contracts and environmental manager for Sydney Yard Access Bridge
- Attendance at Sydney Metro meetings with Department of Planning & Environment, Macquarie Bank, 65 Berry Street and Wenona School

***Inspections***

- Victoria Cross, Pitt Street North: 15 May 2017
- Martin Place North: 22 May 2017
  - Issue: tonal movement alarm observed during OOHW at Martin Place (22 May 2017). This is not consistent with the Sydney Metro Construction Noise and Vibration Strategy (Table 9) which requires non-tonal alarms for any OOH work. This was judged to be a minor issue at this site as there are no residential receivers nearby, but was highlighted to the Sydney Metro environmental management team for resolution and reiterated in subsequent OOH approvals.

***Non-compliance and incident details***

None

***Ongoing and upcoming environmental risks;***

- Ongoing review of CNVIS documents for Delta works
- Site inspections and observations during initial demolition works and SYAB

***Recommendations (incl auditing)***

None